



신·재생에너지  
New & Renewable Energy

## 신 · 재생에너지설비 인증서

1. 업 체 명 (사업자등록번호) : 대흥테크뉴(주) (1148152806)
2. 사무소 소재지 : 서울시 서초구 반포동 746-8
3. 공장 소재지 : No. 88, Qifeng Rd. Rucheng Town, Rugao City, Jiangsu Province, 226500, P.R. China
4. 인증 신 · 재생에너지 설비

### 제품의 특징

셀사양: JA solar Holding Co., Ltd., 72개 다결정, 156×156, 4.38, 모듈크기 (mm): 1,956×992×50, 무게 (kg): 27, 정격효율 (%): 15.98, 정격출력 (W): 310, 최대시스템전압 (V): 1,000, 개방전압 (V): 45.5, 최대출력동작전압 (V): 36.9, 단락전류 (A): 8.85, 최대출력동작전류 (A): 8.41

인증대상 품 목 : 결정질 태양전지 모듈  
모 델 명 : AS-6P-310W  
적 용 기 준 : PV 101 : 2013

2016년 05월 02일

한국에너지공단 부설  
신재생에너지센터소장



◇재발급 이력

1

\* 이 모델의 인증서 유효기간은 2019-05-01 입니다.

본 인증서에 명시된 제품은 신재생에너지법 개정법률[제13087호, 2015.1.28] 부칙 제3조의 규정에 의거하여 해당 업체에 대한 KS인증 전환심사 완료일까지 산업표준화법에 따른 KS인증을 받은 제품으로 간주함

Certificate No : PV-CPM-1-1983



## Certificate of N&R Energy Facility

- ① Company Name (Company ID No) : Daehong Technew Corp(1148152806)
- ② Office Address : No. 88, Qifeng Rd. Rucheng Town, Rugao City, Jiangsu Province, 226500, P.R. China
- ③ Factory Address : No. 88 Qifeng rd. Rucheng Town Rugao, Jiangsu
- ④ Certified Facility

Characteristics  
of the facility

Cell:JA Solar Holding Co., Ltd., 72개 다결정, 156×156, 4.29, Module size (mm):1,956×992×50, Weight (kg):27, Rated Efficiency (%):15.46, Pmax (W):300, Max system voltage (V):1,000, Voc (V):45.3, Vmax (V):36.70, Isc (A):8.68, Imax (A):8.18

Facility : Crystalline photovoltaic module  
Model : AS-6P-300W  
Test Standard : PV 101 : 2014

2015-11-20

New & Renewable Energy Center



◇Reissued history

1

\* Expiry date : 2018-11-19

Certificate No : PV-CPM-1-1984



## Certificate of N&R Energy Facility

- ① Company Name (Company ID No) : Daehong Technew Corp(1148152806)
- ② Office Address : No. 88, Qifeng Rd. Rucheng Town, Rugao City, Jiangsu Province, 226500, P.R. China
- ③ Factory Address : No. 88 Qifeng rd. Rucheng Town Rugao, Jiangsu
- ④ Certified Facility

Characteristics of the facility
Cell:JA Solar Holding Co., Ltd., 60개 다결정, 156×156, 4.29, Module size (mm):1,640×992×40, Weight (kg):18.5, Rated Efficiency (%):15.37, Pmax (W):250, Max system voltage (V):1,000, Voc (V):38.0, Vmax (V):30.3, Isc (A):8.75, Imax (A):8.26

Facility : Crystalline photovoltaic module  
Model : AS-6P30-250W  
Test Standard : PV 101 : 2014

2015-11-20

# New & Renewable Energy Center



◇Reissued history  
1

\* Expiry date : 2018-11-19